

No. 10166199-INC 19-2807

**Issued to:**

"NPP Bresler" LLC (ООО "НПП Бреслер")  
Afanasiev street 13  
428000 Cheboksary  
Russian Federation

**For the server product:**

Bresler-0107.603 (Бреслер-0107.603)  
Bay control and protection unit  
Software version: 3  
S/N: 8115/6030014

The server product has not been shown to be non-conforming to:

## IEC 61850 Edition 2 Parts 6, 7-1, 7-2, 7-3, 7-4 and 8-1

Communication networks and systems for power utility automation

The conformance test has been performed according to IEC 61850-10 Edition 2, the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL<sup>2</sup> 1.2.6 with product's protocol, model and technical issue implementation conformance statements: "Protocol Implementation Conformance Statement for the IEC 61850 interface in Bresler-0107.603, 1 jun 2019", "Model Implementation Conformance Statement for the IEC 61850 interface in Bresler-0107.603, 1 jun 2019" and "Technical Issues Implementation Conformance Statement for the IEC 61850 interface in Bresler-0107. 603, 1 jun 2019" and the extra information for testing: "Protocol Implementation eXtra Information for Testing (PIXIT) for the IEC 61850 interface in Bresler-0107.511, 1 jun 2019".


The following IEC 61850 conformance blocks have been tested with a positive result (number of relevant and executed test cases / total number of test cases):

1 Basic Exchange (25/26)	9a GOOSE Publish (11/13)
2 Data Sets (4/7)	9b GOOSE Subscribe (14/14)
2+ Data Set Definition (24/24)	12a Direct Control (9/18)
3 Substitution (3/3)	12b SBO Control (16/27)
4 Setting Group Selection (4/4)	12c Enhanced Direct control (11/20)
4+ Setting Group definition (12/13)	12d Enhanced SBO control (18/28)
5 Unbuffered Reporting (21/21)	13 Time Synchronization (6/7)
6 Buffered Reporting (30/30)	14 File Transfer (5/8)

This certificate includes a summary of the test results as carried out at R&D CENTER @ FGC UES in the Russian Federation with UniGrid SA Simulator 1.4.453 with test suite 1.0.49 and UniCA 61850 Analyzer 5.34.01. This document has been issued for information purposes only, and the archived DNV GL verification report No. 10166199-INC 19-2806 will prevail.

The test has been carried out on one single specimen of the product as referred above and submitted to DNV GL by "NPP Bresler" LLC. The manufacturer's production process has not been assessed. This certificate does not imply that DNV GL has approved any product other than the specimen tested.

Arnhem, August 22, 2019



**N.A. Heijker**  
Business Leader  
Interoperability of Smart Power Systems

**Issued by:**



DNV KEMA is now DNV GL



**R. Schimmel**  
Verification Manager

<sup>1</sup> Level A - Independent test lab with certified ISO 9001 Quality System

<sup>2</sup> TPCL - Test procedures change list

Copyright © DNV GL Netherlands B.V. Arnhem, the Netherlands. All rights reserved. It is prohibited to update or change this certificate in any manner whatsoever, including but not limited to dividing it into parts.

Applicable Test Procedures from the UCA International Users Group Edition 2 Server Test Procedures version 1.0 with TPCL 1.2.6

Conformance Block	Mandatory	Conditional
1: Basic Exchange	sAss1, sAss2, sAss3, sAssN2, sAssN3, sAssN4, sAssN5, sSrv1, sSrv2, sSrv3, sSrv4, sSrv5, sSrvN1abcd, sSrvN4	sAssN6, sSrv6, sSrv8, sSrv9, sSrv10, sSrv12, sSrv13, sSrvN1e, sSrvN1f, sSrvN2, sSrvN3
2: Data Sets	sDs1, sDs10a, sDsN1ae	sDs15
2+: Data Set Definition	sDs2, sDs3, sDs4, sDs5, sDs6, sDs7, sDs8, sDs9, sDs11, sDs13, sDs14, sDsN1cd, sDsN2, sDsN3, sDsN4, sDsN5, sDsN6, sDsN7, sDsN8, sDsN9, sDsN10	sDs12, sDsN11, sDsN12
3: Substitution	sSub1, sSub2, sSub3	
4: Setting Group Selection	sSg1, sSg3, sSgN1	sSg11
4+: Setting Group Definition	sSg2, sSg4, sSg7, sSg8, sSg10, sSg12, sSgN2, sSgN3, sSgN4, sSgN5	sSg6, sSg9
5: Unbuffered Reporting	sRp1, sRp2, sRp3, sRp4, sRp5, sRp9, sRp14, sRp15, sRpN1, sRpN2, sRpN3, sRpN4, sRpN8	sRp6, sRp7, sRp8, sRp10, sRp11, sRp12, sRp13, sRpN5
6: Buffered Reporting	sBr1, sBr2, sBr3, sBr4, sBr5, sBr9, sBr14, sBr15, sBr20, sBr21, sBr22, sBr25, sBr26, sBr27, sBr28, sBrN1, sBrN2, sBrN3, sBrN4, sBrN5, sBrN8	sBr6, sBr7, sBr8, sBr10, sBr11, sBr12, sBr13, sBr23, sBr24
9a: GOOSE publish	sGop2a, sGop3, sGop4, sGop9, sGop10, sGop11	sGop1, sGop2b, sGop6, sGop7, sGopN1
9b: GOOSE subscribe	sGos1, sGos2, sGos3, sGos5, sGos6a, sGos7, sGosN1, sGosN2, sGosN3, sGosN4, sGosN5, sGosN6	sGos4, sGos6b
12a: Direct control	sCtl5, sCtl10, sDOns1, sDOns2	sCtl7, sCtl15, sCtl16, sCtl17, sCtl18
12b: SBO control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOns1, sSBOns2, sSBOns6	sCtl4, sCtl6, sCtl7, sCtl15, sCtl16, sCtl17, sCtl18
12c: Enhanced Direct Control	sCtl5, sCtl10, sDOes1, sDOes2	sCtl7, sCtl14, sCtl15, sCtl16, sCtl17, sCtl18, sCtl26
12d: Enhanced SBO Control	sCtl5, sCtl8, sCtl9, sCtl10, sCtl11, sCtl25, sSBOes1, sSBOes2, sSBOes6, sSBOes8	sCtl4, sCtl6, sCtl7, sCtl15, sCtl16, sCtl17, sCtl18, sCtl26
13: Time sync	sTm1, sTm2, sTmN1	sTm3, sTm5, sTmN2
14: File transfer	sFt1, sFt2ab, sFt4, sFt5, sFtN1ab	